

13, Kiddles, YEOVIL, BA21 4EP

Dwelling type: Top-floor flat
Date of assessment: 06 February 2019
Date of certificate: 07 February 2019

Reference number: 0868-9067-7282-6521-6934
Type of assessment: RdSAP, existing dwelling
Total floor area: 37 m²

Use this document to:


- Compare current ratings of properties to see which properties are more energy efficient
- Find out how you can save energy and money by installing improvement measures

Estimated energy costs of dwelling for 3 years:	£ 1,920
Over 3 years you could save	£ 792

Estimated energy costs of this home			
	Current costs	Potential costs	Potential future savings
Lighting	£ 126 over 3 years	£ 126 over 3 years	
Heating	£ 504 over 3 years	£ 531 over 3 years	
Hot Water	£ 1,290 over 3 years	£ 471 over 3 years	
Totals	£ 1,920	£ 1,128	

These figures show how much the average household would spend in this property for heating, lighting and hot water and is not based on energy used by individual households. This excludes energy use for running appliances like TVs, computers and cookers, and electricity generated by microgeneration.

Energy Efficiency Rating



Top actions you can take to save money and make your home more efficient

Recommended measures	Indicative cost	Typical savings over 3 years
1 Increase loft insulation to 270 mm	£100 - £350	£ 84
2 Insulate hot water cylinder with 80 mm jacket	£15 - £30	£ 555
3 High heat retention storage heaters	£800 - £1,200	£ 153

To receive advice on what measures you can take to reduce your energy bills, visit www.simpleenergyadvice.org.uk or call freephone **0800 444202**. The Green Deal may enable you to make your home warmer and cheaper to run.