

# Energy performance certificate (EPC)

|                                                       |                           |                                                     |
|-------------------------------------------------------|---------------------------|-----------------------------------------------------|
| Flat 7<br>The Three Kings Court<br>BRISTOL<br>BS1 5AY | Energy rating<br><b>E</b> | Valid until: <b>5 May 2032</b>                      |
|                                                       |                           | Certificate number: <b>2831-3133-0151-0887-9435</b> |

|                  |                  |
|------------------|------------------|
| Property type    | Mid-floor flat   |
| Total floor area | 39 square metres |

## Rules on letting this property

Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

## Energy rating and score

This property's energy rating is E. It has the potential to be D.

[See how to improve this property's energy efficiency.](#)

| Score | Energy rating | Current | Potential |
|-------|---------------|---------|-----------|
| 92+   | A             |         |           |
| 81-91 | B             |         |           |
| 69-80 | C             |         |           |
| 55-68 | D             |         | 67 D      |
| 39-54 | E             | 46 E    |           |
| 21-38 | F             |         |           |
| 1-20  | G             |         |           |

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

## Breakdown of property's energy performance

## Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

| Feature              | Description                                    | Rating    |
|----------------------|------------------------------------------------|-----------|
| Wall                 | Solid brick, as built, no insulation (assumed) | Very poor |
| Window               | Single glazed                                  | Very poor |
| Main heating         | Electric storage heaters                       | Average   |
| Main heating control | Automatic charge control                       | Average   |
| Hot water            | Electric immersion, off-peak                   | Very poor |
| Lighting             | Low energy lighting in all fixed outlets       | Very good |
| Roof                 | (another dwelling above)                       | N/A       |
| Floor                | (other premises below)                         | N/A       |
| Secondary heating    | Portable electric heaters (assumed)            | N/A       |

## Primary energy use

The primary energy use for this property per year is 720 kilowatt hours per square metre (kWh/m2).

► [About primary energy use](#)

## How this affects your energy bills

An average household would need to spend **£1,072 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £436 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2022** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

## Heating this property

Estimated energy needed in this property is:

- 7,599 kWh per year for heating
- 1,397 kWh per year for hot water

## Impact on the environment

This property's environmental impact rating is F. It has the potential to be E.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.

## Carbon emissions

|                                      |                   |
|--------------------------------------|-------------------|
| An average household produces        | 6 tonnes of CO2   |
| This property produces               | 4.8 tonnes of CO2 |
| This property's potential production | 2.6 tonnes of CO2 |

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

# Steps you could take to save energy

► [Do I need to follow these steps in order?](#)

## Step 1: Internal or external wall insulation

Typical installation cost £4,000 - £14,000

Typical yearly saving £313

Potential rating after completing step 1

61 D

## Step 2: Draught proofing

Typical installation cost £80 - £120

Typical yearly saving £8

Potential rating after completing steps 1 and 2

62 D

## Step 3: Double glazed windows

Replace single glazed windows with low-E double glazed windows

Typical installation cost £3,300 - £6,500

Typical yearly saving £88

Potential rating after completing steps 1 to 3

66 D

## Step 4: High performance external doors

Typical installation cost £1,000

Typical yearly saving £28

Potential rating after completing steps 1 to 4

67 D

## Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

## More ways to save energy

[Find ways to save energy in your home](#)

## Who to contact about this certificate

### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

|                 |                                                                              |
|-----------------|------------------------------------------------------------------------------|
| Assessor's name | Leslie Clarke                                                                |
| Telephone       | 07587878296                                                                  |
| Email           | <a href="mailto:les.clarke@clarkeprop.co.uk">les.clarke@clarkeprop.co.uk</a> |

## Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

|                      |                                                      |
|----------------------|------------------------------------------------------|
| Accreditation scheme | ECMK                                                 |
| Assessor's ID        | ECMK301988                                           |
| Telephone            | 0333 123 1418                                        |
| Email                | <a href="mailto:info@ecmk.co.uk">info@ecmk.co.uk</a> |

## About this assessment

|                        |                         |
|------------------------|-------------------------|
| Assessor's declaration | No related party        |
| Date of assessment     | 6 May 2022              |
| Date of certificate    | 6 May 2022              |
| Type of assessment     | ► <a href="#">RdSAP</a> |

## Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at [mhclg.digital-services@communities.gov.uk](mailto:mhclg.digital-services@communities.gov.uk) or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

|                    |                                                                                         |
|--------------------|-----------------------------------------------------------------------------------------|
| Certificate number | <a href="#">8028-7224-2900-2890-5922 (/energy-certificate/8028-7224-2900-2890-5922)</a> |
| Valid until        | 19 April 2028                                                                           |
| Certificate number | <a href="#">8724-7229-2909-2866-5906 (/energy-certificate/8724-7229-2909-2866-5906)</a> |
| Expired on         | 6 November 2024                                                                         |

[Help \(/help\)](#) [Accessibility \(/accessibility-statement\)](#) [Cookies \(/cookies\)](#)

[Give feedback \(https://forms.office.com/e/KX25htGMX5\)](https://forms.office.com/e/KX25htGMX5) [Service performance \(/service-performance\)](#)

### OGI

All content is available under the [Open Government Licence v3.0](#) (<https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/>), except where otherwise stated



ht (<https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-frameworkor>