

# Energy performance certificate (EPC)

52, Brook Street Whiston PRESCOT L35 5AP	Energy rating <h1 style="font-size: 2em; margin: 0;">D</h1>	Valid until: <b>28 July 2026</b> <hr/> Certificate number: <b>0444-2861-7835-9226-1151</b>
---	--	---

Property type	Mid-terrace house
Total floor area	63 square metres

## Rules on letting this property

Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance) (<https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance>).

## Energy rating and score

This property's energy rating is D. It has the potential to be C.

[See how to improve this property's energy efficiency.](#)

The graph shows this property's current and potential energy rating.

**Properties get a rating from A (best) to G (worst) and a score.** The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

the average energy rating is D  
 the average energy score is 60

Score	Energy rating	Current	Potential
92+	A		
81-91	B		
69-80	C		80 C
55-68	D	60 D	
39-54	E		
21-38	F		
1-20	G		

## Breakdown of property's energy performance

### Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Cavity wall, filled cavity	Good
Roof	Pitched, no insulation (assumed)	Very poor
Roof	Flat, insulated (assumed)	Average
Window	Fully double glazed	Average
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Programmer, TRVs and bypass	Average
Hot water	From main system	Good
Lighting	No low energy lighting	Very poor
Floor	Suspended, no insulation (assumed)	N/A
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	Room heaters, mains gas	N/A

### Primary energy use

The primary energy use for this property per year is 317 kilowatt hours per square metre (kWh/m<sup>2</sup>).

### Additional information

Additional information about this property:

- Dwelling may have narrow cavities
-

## How this affects your energy bills

An average household would need to spend **£829 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £178 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2016** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

### Heating this property

Estimated energy needed in this property is:

- 8,111 kWh per year for heating
- 1,904 kWh per year for hot water

### Impact on the environment

This property's environmental impact rating is D. It has the potential to be C.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO<sub>2</sub>) they produce each year.

### Carbon emissions

An average household produces **6 tonnes of CO<sub>2</sub>**

This property produces **3.5 tonnes of CO<sub>2</sub>**

This property's potential production **1.8 tonnes of CO<sub>2</sub>**

You could improve this property's CO<sub>2</sub> emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

### Changes you could make

Step	Typical installation cost	Typical yearly saving
1. Low energy lighting	£75	£36
2. Heating controls (room thermostat)	£350 - £450	£33
3. Condensing boiler	£2,200 - £3,000	£62
4. Flue gas heat recovery	£400 - £900	£23
5. Solar water heating	£4,000 - £6,000	£24

Step	Typical installation cost	Typical yearly saving
6. Solar photovoltaic panels	£5,000 - £8,000	£270

### Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

### More ways to save energy

Find ways to save energy in your home by visiting [www.gov.uk/improve-energy-efficiency](http://www.gov.uk/improve-energy-efficiency).

## Who to contact about this certificate

### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Shaun Hendry
Telephone	08450945192
Email	<a href="mailto:epcquery@vibrantenergymatters.co.uk">epcquery@vibrantenergymatters.co.uk</a>

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	ECMK
Assessor's ID	ECMK300054
Telephone	0333 123 1418
Email	<a href="mailto:info@ecmk.co.uk">info@ecmk.co.uk</a>

### About this assessment

Assessor's declaration	No related party
Date of assessment	29 July 2016
Date of certificate	29 July 2016
Type of assessment	<a href="#">RdSAP</a>