

# ELECTRICAL INSTALLATION CERTIFICATE [BS 7671:2018 as amended]

000014293 - Master



Olwyn Fox 2000

## Details of the Client

Client/Address Northwood, 64 Harrogate Road, Chapel Allerton, Leeds, West Yorkshire, LS7 4LA

## Details of the Installation

Address 4 Vicarage View, Headingley, Leeds, West Yorkshire, LS5 3HF

Extent of the installation covered by this certificate New Mains

The installation is:

New  N/A

An Addition  N/A

An Alteration

## Design

I being the person(s) responsible for the design of the electrical installation (as indicated by my signature(s) below), particulars of which are described above, have exercised reasonable skill and care when carrying out the design hereby CERTIFY that the design work for which I have been responsible is, to the best of my knowledge and belief in accordance with BS 7671 amended to July 2018 (date) except for the departures, if any detailed as follows:

Details of departures from BS 7671, as amended (Regulations 120.3, 133.1.3 and 133.5) none

Details of permitted exceptions (Regulations 411.3.3):

Yes


Where applicable, a suitable risk assessment(s) must be attached to this Certificate:

N/A

Number of pages: n/a

The extent of liability of the signatory or signatories is limited to the work described above as the subject of this certificate.

For the DESIGN of the installation:

Signature  Date 28/05/2020 Name (CAPITALS) D.Hepworth Designer 1

Signature N/A Date N/A Name (CAPITALS) N/A Designer 2 \*\*

\*\* (where there is divided responsibility for the design)


## Construction

I being the person(s) responsible for the construction of the electrical installation (as indicated by my signature(s) below), particulars of which are described above, have exercised reasonable skill and care when carrying out the construction hereby CERTIFY that the construction work for which I have been responsible is, to the best of my knowledge and belief in accordance with BS 7671 amended to July 2018 (date) except for the departures, if any detailed as follows:

Details of departures from BS 7671, as amended (Regulations 120.3, 133.1.3 and 133.5) none

The extent of liability of the signatory is limited to the work described above as the subject of this certificate.

For the CONSTRUCTION of the installation:

Signature  Date 28/05/2020 Name (CAPITALS) D.Hepworth Constructor

## Inspection and Testing

I being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my signature(s) below), particulars of which are described above, have exercised reasonable skill and care when carrying out the inspection and testing hereby CERTIFY that the work for which I have been responsible is, to the best of my knowledge and belief in accordance with BS 7671 amended to July 2018 (date) except for the departures, if any detailed as follows:

Details of departures from BS 7671, as amended (Regulations 120.3, 133.1.3 and 133.5) none

The extent of liability of the signatory is limited to the work described above as the subject of this certificate.

For the INSPECTION AND TESTING of the installation:

Reviewed by

Signature  Date 28/05/2020 Signature  Date 28/05/2020

Name (CAPITALS) D.Hepworth Inspector Name (CAPITALS) R.Lord Qualified Supervisor

## Particulars of the Organisation(s) Responsible for the Electrical Installation

DESIGN (1)	Organisation	Olwyn Fox 2000 Ltd	
Address	55 Commercial Street, Rothwell Leeds. West Yorkshire LS26 0QD		Tel 0113 2823159
NICEIC Enrolment Number	7630		Branch No.(If Applicable) N/A
DESIGN (2)	Organisation	N/A	
Address			Tel N/A
Registration Number	N/A		Branch No.(If Applicable) N/A
CONSTRUCTION	Organisation	Olwyn Fox 2000 Ltd	
Address	55 Commercial Street, Rothwell Leeds. West Yorkshire LS26 0QD		Tel 0113 2823159
NICEIC Enrolment Number	7630		Branch No.(If Applicable) N/A
INSPECTION AND TESTING	Organisation	Olwyn Fox 2000 Ltd	
Address	55 Commercial Street, Rothwell Leeds. West Yorkshire LS26 0QD		Tel 0113 2823159
NICEIC Enrolment Number	7630		Branch No.(If Applicable) N/A

## Supply Characteristics and Earthing Arrangements

Tick boxes and enter details, as appropriate

System Type(s)	Number and Type of Live Conductors				Nature of Supply Parameters				Characteristics of primary supply overcurrent protective Device(s)					
TN-S	N/A	a.c.	<input checked="" type="checkbox"/>	d.c.	<input checked="" type="checkbox"/>	Nominal Voltage	$U^{(1)}$	N/A	V	$U_o^{(1)}$	230	V	BS(EN)	
TN-C-S	<input checked="" type="checkbox"/>	1-Phase (2 wire)	<input checked="" type="checkbox"/>	1-Phase (3 wire)	N/A	2 Pole	N/A	Nominal frequency	$f^{(1)}$	50	Hz	Type	88-2 Fuse HRC	
TN-C	N/A	2-Phase (3 wire)	N/A	3 Pole	N/A	Prospective fault current	$I_{pf}^{(2)}$	1.77	kA	Rated current	80	A	mG	
TT	N/A	3-Phase (3 wire)	N/A	3-Phase (4 wire)	N/A	Other	N/A	External loop impedance	$Z_e^{(2)}$	0.13	$\Omega$	Short circuit Capacity	80	kA
IT	N/A	Other	N/A			Number of Sources	1	(1) by enquiry (2) by enquiry or by measurement		Confirmation of Supply Polarity	<input checked="" type="checkbox"/>			

## Particulars of Installation at the Origin

<b>Means of Earthing</b>		<b>Details of Installation Earth Electrode (where applicable)</b>				
Distributor's facility	<input checked="" type="checkbox"/>	Type (eg rod(s), tape etc)	N/A		Location	N/A
Installation earth electrode	N/A	Electrode resistance, $R_A$	N/A $\Omega$		Method of measurement	N/A
<b>Main Switch/ Switch-Fuse/ Circuit-Breaker/ RCD</b>			<b>Maximum Demand (Load)</b>		<b>Protective measure(s) against electric shock</b>	
Type BS(EN)	5419 Isolator	Voltage Rating	230 V		80 Amps	
No. of poles	2	Rated Current, $I_n$	100 A		ADS	
Supply Conductors material	Copper	RCD operating current, $I_{\Delta n}$	N/A mA		<b>Earthing conductor</b>	
Supply Conductors CSA	25 mm <sup>2</sup>	RCD operating time at, $I_{\Delta n}$	N/A ms		Conductor material: Copper	
		Rated time delay	N/A ms		Conductor csa: 16 mm <sup>2</sup>	
					Continuity verified <input checked="" type="checkbox"/>	
					Connection verified <input checked="" type="checkbox"/>	
					<b>Main protective bonding conductors</b>	
					Conductor material: Copper	
					Conductor csa: 10 mm <sup>2</sup>	
					Continuity verified <input checked="" type="checkbox"/>	
					Connection verified <input checked="" type="checkbox"/>	
					<b>Bonding of extraneous conductive parts (✓)</b>	
					Water installation pipes <input checked="" type="checkbox"/>	
					Lightning Protection <input type="checkbox"/>	
					Oil installation pipes <input type="checkbox"/>	
					Structural Steel <input type="checkbox"/>	
					Gas installation pipes <input checked="" type="checkbox"/>	
					Other <input type="checkbox"/> N/A	

## Comments on Existing Installation:

In the case of an addition or alteration see regulation 644.1.2: --See Additional Page--

## Next Inspection

I, the designer(s) RECOMMEND that this installation is further inspected and tested after an interval of not more than 5 Years or change of tenancy.

Item No	Description	Outcome	Item No	Description	Outcome
1.0	<b>External condition of electrical intake equipment (visual inspection only)</b> (If inadequacies are identified with the intake equipment it is recommended the person ordering the report informs the appropriate authority.)		6.0	<b>Basic and fault protection</b>	
1.1	Service cable	✓	a)	SELV	✓
1.2	Service head	✓	b)	PELV	✓
1.3	Earthing arrangement	✓	c)	Double insulation	✓
1.4	Meter tails	✓	d)	Reinforced insulation	✓
1.5	Metering equipment	✓	7.0	<b>Distribution equipment</b>	
1.6	Isolator (where present)	N/A	7.1	Working space/accessibility adequate/satisfactory	✓
2.0	<b>Parallel or switched alternative sources of supply</b>		7.2	Security of fixing	✓
2.1	Presence of adequate arrangements where generator to operate as a switched alternative:		7.3	Insulation of live parts not damaged during erection	✓
a)	Dedicated earthing arrangement independent of that of the public supply	N/A	7.4	Adequacy/security of barriers	✓
2.2	Presence of adequate arrangements where generator to operate in parallel with public supply system:		7.5	Suitability of enclosures for IP and fire ratings	✓
a)	Correct connection of generator in parallel	N/A	7.6	Enclosures not damaged during installation	✓
b)	Compatibility of characteristics of means of generation	N/A	7.7	Presence and effectiveness of obstacles	✓
c)	Means to provide automatic disconnection of generator in the event of loss of public supply or voltage or frequency deviation beyond declared values	N/A	7.8	Main switch(es): presence and operation (functional check)	✓
d)	Means to prevent connection of generator in the event of loss of public supply or voltage or frequency deviation beyond declared values	N/A	7.9	Components are suitable according to manufacturers' assembly instructions or literature	✓
e)	Means to isolate generator from public supply	N/A	7.10	Circuit-breaker and RCDs operation to prove functionality	✓
2.3	Presence of alternative/additional supply warning notices at or near:		7.11	RCD(s) provided for fault protection where specified	✓
a)	The origin	N/A	7.12	RCD(s) provided for protection against the risk of fire where present	✓
b)	The meter position if remote from origin	N/A	7.13	RCD(s) provided for additional protection where specified	✓
c)	The consumer unit/distribution board to which the alternative/additional sources are connected	N/A	7.14	Confirmation overvoltage protection (SPDs) provided where specified	N/A
d)	All points of isolation of ALL sources of supply	N/A	7.15	SPDs functioning/operating as expected	N/A
3.0	<b>Automatic disconnection of supply</b>		7.16	Selection of protective devices(s) and base(s); correct type and rating	✓
3.1	Presence and adequacy of protective earthing/bonding arrangements as follows:		7.17	Single-pole protective devices in line conductors only	✓
a)	Distributor's earthing arrangement or installation earth electrode arrangement	N/A	7.18	Protection against mechanical damage where cables enter equipment	✓
b)	Earthing conductor and connections	✓	7.19	Protection against electromagnetic effects where cables enter ferromagnetic enclosures	✓
c)	Main protective bonding conductors and connections	✓	7.20	Confirmation that ALL conductor connections including connections to busbars are correctly located in terminals and are tight and secure	✓
d)	Earthing/bonding labels at all appropriate locations	✓	7.21	Presence of RCD six-monthly test notice where required	✓
3.2	Accessibility of:		7.22	Presence of diagrams, charts or schedules at or near each distribution board where required	✓
a)	Earthing conductor connections	✓	7.23	Presence of next inspection recommendation label	✓
b)	All protective bonding connections	✓	7.24	Presence of non-standard (mixed) cable colour warning notice at or near the appropriate distribution board where required	N/A
3.3	FELV-requirements satisfied	✓	7.25	Presence of other required labelling	N/A
3.4	Nominal line to line voltage does not exceed 110V and the nominal line to earth voltage does not exceed 63.5V	N/A			
4.0	<b>Basic protection</b>				
4.1	Provisions for basic protection where specified:				
a)	Insulation of live parts	✓			
b)	Barriers or enclosures	✓			
c)	Obstacles	✓			
d)	Placing out of reach	N/A			
5.0	<b>Additional protection</b>				
5.1	The presence and effectiveness of additional protection methods used as follows:				
a)	RCDs should not exceed 30 mA	✓			
b)	Supplementary bonding	✓			









Comments on Existing Installation

Installation with various additions and alterations,

**ELECTRICAL INSTALLATION CERTIFICATE  
GUIDANCE FOR RECIPIENTS (to be appended to the Certificate)**

This safety Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with British Standard 7671 (the IET Wiring Regulations).

You should have received an 'original' Certificate and the contractor should have retained a duplicate. If you were the person ordering the work, but not the owner of the installation, you should pass this Certificate, or a full copy of it including the schedules, immediately to the owner.

The "original" Certificate should be retained in a safe place and be shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this Certificate will demonstrate to the new owner that the electrical installation complied with the requirements of British Standard 7671 at the time the Certificate was issued. The Construction (Design and Management)

Regulations require that, for a project covered by those Regulations, a copy of this Certificate, together with schedules, is included in the project health and safety documentation.

For safety reasons, the electrical installation will need to be inspected at appropriate intervals by a skilled person or persons, competent in such work. The maximum time interval recommended before the next inspection is stated on Page 1 under 'NEXT INSPECTION'.

This Certificate is intended to be issued only for a new electrical installation or for new work associated with an addition or alteration to an existing installation. It should not have been issued for the inspection and testing of an existing electrical installation. An 'Electrical Installation Condition Report' should be issued for such an inspection.

This Certificate is only valid if accompanied by the Schedule of Inspections and the Schedule(s) of Test Results.

These notes are based on those seen in Appendix 6 BS 7671:2018 (as amended)