

Energy performance certificate (EPC)

98, Swinnow Road
LEEDS
LS13 4NX

Energy rating

D

Valid until: **12 February 2027**

Certificate number: **8109-5075-9029-7297-9233**

Property type

Semi-detached house

Total floor area

93 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance) (<https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance>).

Energy rating and score

This property's current energy rating is D. It has the potential to be B.

[See how to improve this property's energy efficiency.](#)

Score	Energy rating	Current	Potential
92+	A		
81-91	B		81 B
69-80	C		
55-68	D	58 D	
39-54	E		
21-38	F		
1-20	G		

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

the average energy rating is D
the average energy score is 60

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Cavity wall, filled cavity	Good
Wall	Cavity wall, as built, no insulation (assumed)	Poor
Wall	Cavity wall, as built, partial insulation (assumed)	Average
Roof	Pitched, 270 mm loft insulation	Good
Roof	Flat, limited insulation (assumed)	Poor
Window	Partial secondary glazing	Poor
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Programmer and room thermostat	Average
Hot water	From main system	Good
Lighting	No low energy lighting	Very poor
Floor	Suspended, no insulation (assumed)	N/A
Floor	To unheated space, no insulation (assumed)	N/A
Secondary heating	Room heaters, electric	N/A

Primary energy use

The primary energy use for this property per year is 292 kilowatt hours per square metre (kWh/m²).

Environmental impact of this property

This property's current environmental impact rating is E. It has the potential to be C.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO₂) they produce each year. CO₂ harms the environment.

An average household produces 6 tonnes of CO₂

This property produces 4.7 tonnes of CO₂

This property's potential production 2.1 tonnes of CO₂

You could improve this property's CO₂ emissions by making the suggested changes. This will help to protect the environment.

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

Changes you could make

Step	Typical installation cost	Typical yearly saving
1. Flat roof or sloping ceiling insulation	£850 - £1,500	£39
2. Cavity wall insulation	£500 - £1,500	£71
3. Floor insulation (suspended floor)	£800 - £1,200	£78
4. Draught proofing	£80 - £120	£25
5. Low energy lighting	£35	£50
6. Heating controls (TRVs)	£350 - £450	£39
7. Solar water heating	£4,000 - £6,000	£32
8. Replace single glazed windows with low-E double glazed windows	£3,300 - £6,500	£60
9. Solar photovoltaic panels	£5,000 - £8,000	£262

Paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

Estimated energy use and potential savings

Based on average energy costs when this EPC was created:

Estimated yearly energy cost for this property	£1137
--	-------

Potential saving if you complete every step in order	£394
--	------

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

Heating use in this property

Heating a property usually makes up the majority of energy costs.

Estimated energy used to heat this property

Type of heating	Estimated energy used
-----------------	-----------------------

Space heating	13703 kWh per year
---------------	--------------------

Water heating	2220 kWh per year
---------------	-------------------

Potential energy savings by installing insulation

Type of insulation	Amount of energy saved
--------------------	------------------------

Cavity wall insulation	1194 kWh per year
------------------------	-------------------

Saving energy in this property

Find ways to save energy in your home by visiting www.gov.uk/improve-energy-efficiency.

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name	Tina McNally
Telephone	07872198164
Email	tm@manningstainton.co.uk

Accreditation scheme contact details

Accreditation scheme	ECMK
Assessor ID	ECMK301079
Telephone	0333 123 1418
Email	info@ecmk.co.uk

Assessment details

Assessor's declaration	Employed by the professional dealing with the property transaction
Date of assessment	13 February 2017
Date of certificate	13 February 2017
Type of assessment	RdSAP
