



Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. No detailed internal inspection of flues (firebricks, constructions and lining) has been carried out.

Certificate Performance

3 Baillihill Rd 116

Certificate No: Bk436

Engineers' Details		Installation Details		Client Details	
Trading Title	Davidson Gas Services Ltd	Installation Address	3 Bailliehill Place Kilmarnock	Client Address	Lomond Property 26 Parkhouse St Ayr
Address	1/1 64 Fort St Ayr Ayr Pro		Post Code: KA12LU		Post Code: KA7 2HH
Gas Safe No:	232860	Telephone No:	07815140402	Telephone No:	01292280855

Appliance Details				Inspection Details												
Location	Appliance Type	Make	Model	CO2 Reading	CO Reading	FlueType (OF/RS/FL)	Appliance Inspected (YES/NO/NA)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure(mbar) or Heat Input(KW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
Kitchen	Combi boiler	ALPHA	Intec 28xe			RS	YES	0.0004	YES	21 mbar	YES	YES	YES	PASS	YES	YES
Kitchen	Hob	Hotpoint	N/a			FL	YES	0.0002	YES	21 mbar	YES	YES	N/A	N/A	YES	YES
Faults/Notes				Remedial Work Taken												
1	New carbon monoxide alarm installed.			Warning Notice Fixed												
2				NA												
3																
4																
5																

Emergency Control Valve accessible:	☐ YES	Gas Tightness Satisfactory:	☐ YES	Signatures Report Issued By: Name: Brian Kerr Report Received By: Name: campbell Murphy Signed: <input text"="" type="text" value="Thu-22-09-2016"/>	Gas ID Number:	3808251	
Gas Installation Pipework Visual Inspection Satisfactory:	☐ YES	Number Of Appliances Tested:	2		Equipmental Bonding:	☐ NO	Installation Pass:
Next Inspection Due On Or Before:	Fri-22-09-2017	CO Alarm fitted and working?	☐ YES	Smoke alarm fitted	☐ YES	This Gas Safety Report was created by Gas Checker Software 2016 all rights reserved. www.gaschecker.co.uk	